

## **BUILDING OVERVIEW**

STT Jakarta 3 (RFS: Q4 2026) is part of the STT Jakarta Data Centre Campus, offering liquid cooling solutions ready to meet the growing demands of Al and high-performance computing workloads.

**Location** Block EA-1, Greenland International

Industrial Centre (GIIC), Cikarang, Bekasi, West Java JB, 17530

Indonesia

Gross Floor Area 181,586 sqft (16,876 sqm)

Net Lettable Area Up to 92,181 sqft (8,567 sqm)

Slab-to-slab Height 6.6 m

Floor Loading 15 kN/sqm

Loading Bays 2
Staging Room 1
Passenger Lifts (630kg) 2
Cargo Lifts (5,000kg) 2

# **FIRE DETECTION AND SUPPRESSION**

VESDA and smoke detectors

Pre-action fire sprinkler system for data hall and NOVEC for electrical plant rooms

2hr fire-rated doors and partitions

Addressable fire alarm system

### **POWER**

N+1 20kV distribution and supported by 150kV substation on campus

Up to 24MW of IT Load

N+1 generators

Fuel tank providing up to 48hrs of support at full load

N+1 UPS with 5-min Lithium-Ion battery back-up

Concurrent maintainable

Fault tolerant

#### COOLING

Design PUE of < 1.30

N+1 water-cooled chillers with concurrently maintainable ring configuration

N+1 fan wall units and CDU with 2N UPS power supplies

Up to 48h of water storage capacity for cooling towers

#### CONNECTIVITY

Carrier-neutral

3 main distribution frame (MDF) rooms

3 diverse fibre points of entry to site

Interconnected within the STT Jakarta data centre campus

Access to multiple carriers, internet exchange (IX), and internet service providers

#### **SECURITY**

Anti-crash boundary wall with anti climb fencing, K12 rated vehicle crash barriers

24x7 CCTV recording at 1080p resolution, pan-tilt-zoom video analytics and kept for 90 days

24x7 on-site manned guards

24x7 controlled site access with 2-factor authentication by pre-authorisation

Contactless card access system with RFID real-time movement tracking within building and biometric access control system

# **TARGETED CERTIFICATIONS & COMPLIANCE**

LEED Gold

ISO 20000

ISO 22301

ISO 27001

ISO 50001

SS 564

POJK Audit Assessment

IDX Audit Assessment

TVRA Assessment

PCI DSS

# CONTACT

**E** info@sttelemediagdc.com **W** sttelemediagdc.com

All information contained in this factsheet ("Information") is for information purposes only, and is not intended to constitute an offer or contract of any kind. STT GDC does not warrant the accuracy, adequacy or completeness of the Information and expressly disclaims all liabilities relating to the Information. STT GDC shall in no event be liable for any damages, loss or expense however caused arising from, or in connection with, the use of, or reliance on, the Information. No Information or parts of it may be reproduced, distributed, modified or displayed without the prior written permission of STT GDC. © 2025 PT. STT GDC Indonesia.